



Intertek Report No.: 100558255CRT-001a
Date: November 21, 2011

Intertek
3933 US Route 11
Cortland, NY 13045-9717
Telephone: (607) 753-6711
Facsimile: (607) 753-7560
www.intertek-etlsemko.com

**CAPACITY TESTS OF A UNITED STATES THERMOAMP HEAT SIPHON HEAT PUMP POOL HEATER
MODEL NUMBER Z575HP
SERIAL NUMBER 11K013**

United States ThermoAmp, Inc.
Attn.: Mr. Brody Bernardi
1223 Walnut Street
Latrobe, PA 15650

Phone No.: 724-537-3500
E-Mail Address: brody@heatsiphon.com

General

This Report gives the results of a High and Low Temperature Capacity Test for a HEAT SIPHON Model Z575HP / Serial 11K013 Heat Pump Pool Heater. The work was authorized by Quote No. 500341182 and testing was coordinated through client's representative, Mr. Nathan Yacobucci.

The client supplied the sample, which was assumed to be in new condition.

Test Method

The Capacity Tests were conducted in accordance with ANSI/ASHRAE Standard 146-2006, and AHRI Standard 1160(I-P)- 2009.

The pool heater had water piped to it and psychometric samplers were put next to the unit to measure the ambient temperature.

- Notes: (1) The results contained in the report are for technical evaluation only and are applicable only to the specific test specimen referenced within the report.
- (2) The tests reported have not been performed at the request of the Air-Conditioning, Heating, and Refrigeration Institute, and use of these findings by United States ThermoAmp, Inc. in any advertising or other literature shall state that the test is not part of the AHRI Certification Program.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only the sample tested. This report by itself does not imply that the material, product or service is or has ever been under an Intertek certification program.

Results of Tests

	High Temperature	Low Temperature
Air Temperatures, °F Adjacent to Inlet of Test Unit		
Indoor, Dry-Bulb	81.00	50.10
Indoor, Wet-Bulb	71.52	44.34
Barometer, Hg	28.678	28.731
Water Temperatures, °F		
Water Temperature Inlet	79.91	79.80
Water Temperature Outlet	84.13	82.78
Water Flow rate, GPM	54.01	53.92
Electrical Input		
Test Voltage, Volts	228	228
Line Current, Amps	26.2	26.3
Power Input, Watts	5,654	5,665
Frequency, Hertz	60	60
Performance		
Total Capacity, Btuh	114,069	80,563
Coefficient of Performance	5.913	4.168

Conclusion

The results of these tests are for technical evaluation by United States ThermoAmp, Inc. only and are applicable only to the specific test specimens described.


Date of Tests: November 15, 2011

Tests Supervised by:



John Rowe
Technician Team Leader

Report Approved by:



Robert Hill
Project Engineer